

DESC.	MANUF.	PART #	PART DESC.
TS1-TS4	WHITE-ROGERS	1609-105	THERMOSTAT SWITCH
*TS1-TS4	JOHNSTON	A419GBF-1C	THERMOSTAT SWITCH
PS1-PS8	COPELAND	085-CP2M-7A	PRESSURE SWITCH
FU1-FU4	BUSSMAN	BM6033SQ	3 POLE FUSE BLOCK
FU1-FU4	BUSSMAN	FLQ30	FUSE
FU5	BUSSMAN	BM6033SQ	3 POLE FUSE BLOCK
FU5	BUSSMAN	FLM10	FUSE
FU8	FURNAS	42CF35AJBLE	2 POLE FUSE BLOCK
FU8	BUSSMAN	FLM3	FUSE
FU9	FURNAS	42CF35AJBLE	2 POLE FUSE BLOCK
FU9	BUSSMAN	KTK10	FUSE
FU10	BUSSMAN	FLM15	FUSE
C1-C4	ABB	DP40C3PF	3 POLE CONTACTOR
C7	SIEMENS	3RT1016-1AB01	3 POLE CONTACTOR
OL1	SIEMENS	3RB2016-1SB0	OVERLOAD RELAY
DB1	BUSSMAN	16321-3	3 POLE DIST. BLOCK
TB1	BUSSMANN	TB200-4	4 POLE BARRIER STRIP
TB2	BUSSMANN	TB200-8	8 POLE BARRIER STRIP
XFMER1	SIEMENS	MTO250B	TRANSFORMER
SS1	SIEMENS	3SB2500-2PA11	2 POSITION MAINT. SELECTOR SWITCH
SS1	SIEMENS	3SB3400--B	

rite-temp
water chillers

Rite-Temp Manufacturing
P.O. Box 1275 Rogers, AR.
72757 - 1275
(800) 462-3120 / (479) 636-5199
www.ritetemp.com

CAD DWG FILE C:\DOCUMENTS AND SETTINGS\JLL2\MY DOCUMENTS\AUTOCAD DOCS\AUTOCAD E PROJECTS\RITE TEMP\RTR-1603\RTR-1603-2.DWG

NO.	DATE	REVISION	BY

DWG TITLE
RTS-1604,2004,2404
RTR-1604,2004,2404
Water Chiller
Panel Layout & BOM

ENGINEER	CHECKED BY TC
JOB NO	DRAWN BY JLL
SCALE T/F	DATE 11/18/08
DWG NO	RTR-1604-2
SHEET NO	2 OF 2